

July 29, 2008

CREST PRECAST, INC.
STEVE MADER
609 KISTLER DR
LA CRESCENT MN 55947-1721

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: CREST PRECAST, INC.
Product Name: HOLDING, PUMP OR SIPHON
Model Number(s): 10500
(125.0" L.L., 86 GAL/IN., 84" MAX. DEPTH OF BURY)
Product File No: 20080345

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of AUGUST 2013.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Neenah Foundry gasketed access cover.
 - Bilco locking hinged access cover.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Four inch discharge opening in riser.
 - Dual inlets at end of tank with one access opening above both inlets.
 - Dual outlets at end of tank with one access opening above each outlet.
 - Side outlets for dose tanks.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Six, eight and ten-inch inlet and outlet openings.
 - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on 8/28/2003 under product file number 20030285.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030285

CREST PRECAST, INC.
Page 2
July 29, 2008
PRODUCT FILE NO. 20080345

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov